



DOOR ELEVATION - DELAYED EGRESS
N.T.S.

DOOR HARDWARE

- ① JUNCTION BOX BY OTHERS
- ② SCHLAGE 679-05 DOOR POSITION SWITCH
- ③ VON DUPRIN FIRE RATED 99 SERIES CHEXIT DELAYED EGRESS EXIT DEVICE
- ④ SCHLAGE MT11 OR MT15
- ⑤ NOT USED
- ⑥ VON DUPRIN PS902 X 900-2RS X 900-FA POWER SUPPLY
- ⑦ VON DUPRIN ELECTRIC POWER TRANSER

GENERAL NOTES:

ALL LOW VOLTAGE WIRE TO RUN IN MINIMUM 3/4" CONDUIT OR INSIDE DRYWALL UNLESS NOTED OTHERWISE
 ALL LOW VOLTAGE WIRE TO BE STRANDED WIRE
 ALL GANG BOXES BY ELECTRICAL CONTRACTOR AS REQUIRED
 ALL LOW VOLTAGE WIRING TO BE LABELED CLEARLY AT BOTH END
 ALL MOUNTING HEIGHTS AS SHOWN
 COORDINATE MOUNTING LOCATIONS WITH ELECTRICAL/ARCHITECTURAL PLANS
 ANY DEVIATION FROM HARDWARE SPECIFIED IN SECTION 08710 WILL NEGATE ALL REQUIREMENTS SHOWN
 HEREIN AND REQUIRE NEW DRAWINGS BY OTHERS TO MATCH SUBSTITUTED HARDWARE

OPERATIONAL DESCRIPTION:

DOORS NORMALLY CLOSED AND LOCKED.
 ENTRY BY VALID CREDENTIAL AT PULL SIDE CARD READER.
 AUTHORIZED EGRESS BY VALID CREDENTIAL AT PUSH SIDE CARD READER.
 DELAYED EGRESS LOCKING SYSTEM - DEPRESSING PUSHBAR OF PANIC DEVICE FOR DESIGNATED AMOUNT OF TIME BEGINS IRREVERSIBLE ALARM CYCLE. UPON COMPLETION OF ALARM CYCLE FREE EGRESS IS ALLOWED. DEVICE CAN BE ARMED, RESET OR DISARMED BY ACCESS CONTROL SYSTEM OR MORTISE CYLINDER IN PANIC. DELAY 15 SECONDS PER IBC 1010.1.9.7.
 DELAYED EGRESS SYSTEM UNLOCKS UPON ACTIVATION OF FIRE ALARM ALLOWING EMERGENCY FREE EGRESS.

| | | | |
|---|--------------------------------------|---------------|-------------------------------|
| <p>ALLEGION ELECTRIFIED ELEVATION DRAWINGS</p> | DRAWING: ELEVATION DRAWING | | Checked by: |
| | Drawn By: Jason Relyea DHT, DHC | | DRAWING NO: 5002 |
| | DATE: 03-15-2021 | VERSION: 1 | |
| | SCALE: N.T.S. | REVISION: | |

Wiring Diagram Terms of Use: This information is for professional use only and is intended to be a guide for proper product application and specification. See specific product manuals for proper installation. Any installation should be performed by persons qualified to perform electrical work and in compliance with applicable codes, rules, regulations and orders. Allegion reserves the right to change or modify the information herein without notice. No warranties, express or implied, are provided by Allegion as a result of this information. Any and all use and reproduction of the information herein except for product application and specification is expressly forbidden.