



**Important – Read This First**

- Always check with the local AHJ to make sure that your design meets code for the given address and occupancy
- Always refer to manufacturer instructions, this drawing is a recommendation and site characteristics vary.
- A fire alarm pull station will likely be required inside the vestibule
- Some adjustment of the timing will be necessary by adjusting the Relay 1 and 2 times, installing the device at default values will result in errors.
- Function 50 on the BR3-X is required for correct operation

**RC-04.POE.PwrSup.  
EDK.2xMaglocks.  
BR3X-50.Vestibule.SoftInterlock**

Dwg.No:	Sheet	1	of	1
Date: 3-14-2019	Drawn By: David Tamarchenko	Version: 1.00.00		

**ISONAS**  
PURE IP ACCESS CONTROL

4750 Walnut Street Suite 110  
Boulder, CO 80301  
www.isonas.com