



- Door hardware should maintain mechanical free egress at all times
- Positive voltage for alarm output is wired in parallel so that if one EDK is powered down the alarm will still function
- If current draw of electric strike, EDK, Relay, and Alarm output exceeds 600ma a separate power supply and different wiring scheme will be required

**RC.04.ReadInReadOut.
FreeEgress.LocalAlarm**

Dwg No: 04-EDK-ST-INOUT	Sheet 1	of 1
Date: 6-5-18	Drawn By: David Tamarchenko	Version: 1.00.01

ISONAS
PURE IP ACCESS CONTROL

4750 Walnut Street Suite 110
Boulder, CO 80301
www.isonas.com